



- NOTES:
1. Wrap main and fittings in thrust block zone with two layers of polyethylene film to facilitate future removal.
 2. In lieu of concrete thrust block, restrain pipe or pour concrete straddle block.

NOTE: All material and workmanship shall be in accordance with the current Oregon Standard Specifications

The selection and use of this Standard Drawing, while designed in accordance with generally accepted engineering principles and practices, is the sole responsibility of the user and should not be used without consulting a Registered Professional Engineer.

<p>OREGON STANDARD DRAWINGS CITY OF HOOD RIVER WATER MAIN DEAD-END BLOWOFF ASSEMBLY</p>	
DATE	2002
REVISIONS	
DESCRIPTION	City of Hood River Modifications