



- NOTES:**
1. DEVICE MUST BE SET PLUMB INSIDE METER BOX.
 2. METER BOX MUST BE SIZED TO PROVIDE A MINIMUM CLEARANCE OF 8 INCHES ON TEST COCK SIDE OF DEVICE.
 3. DEVICES LARGER THAN 2 INCHES MUST CONFORM TO OREGON HEALTH DIVISION INSTALLATION SPECIFICATIONS.
 4. METER BOXES SET IN DRIVEWAYS SHALL HAVE TRAFFIC LIDS.

DOUBLE CHECK VALVE ASSEMBLY BACKFLOW PREVENTOR

<p>The selection and use of this Standard Drawing, while designed in accordance with generally accepted engineering principles and practices, is the sole responsibility of the user and should not be used without consulting a Registered Professional Engineer.</p>	<p>NOTE: All material and workmanship shall be in accordance with the current Oregon Standard Specifications.</p>						
<p>OREGON STANDARD DRAWINGS CITY OF HOOD RIVER DOUBLE CHECK VALVE ASSEMBLY INSTALLATION DETAIL</p>	<p>REVISIONS</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 10%;">DATE</th> <th style="width: 90%;">DESCRIPTION</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">12-02</td> <td>City of Hood River Modifications</td> </tr> <tr> <td></td> <td>2002</td> </tr> </tbody> </table>	DATE	DESCRIPTION	12-02	City of Hood River Modifications		2002
DATE	DESCRIPTION						
12-02	City of Hood River Modifications						
	2002						